



**REQUEST FOR PROPOSAL (RFP) NO. 18-008
Water and Wastewater Treatment Chemicals**

Addendum No. 10
Town of Purcellville Specifications Revisions

This Addendum No. 10 revises the chemical specifications for the Town of Purcellville in Section V of RFP #18-008, as follows:

Line Item #	Chemical	Unit	Estimated Quantity per Annum	Unique Chemical Specifications	Applicable Standards	Unique Delivery Requirements
038	Phosphoric Acid	Tons	1-2	The product furnished shall have product content of 85% liquid phosphoric acid (drinking water grade) free of adulterants or impurities which might cause hazards or stoppage in the operation of standard water and wastewater treatment equipment. <ul style="list-style-type: none">• Non-hazardous Inorganic Phosphates 30-50%• Water 50-70%• Clear to slightly turbid, viscous, opaque liquid with a characteristic odor	<ul style="list-style-type: none">• Must meet AWWA Standard B507 (latest edition)• Must meet VDH regulations	The liquid phosphoric acid shall be shipped via tank trucks which meet the cleanliness required in drinking water treatment.

All other terms and conditions of the RFP remain unchanged.