



REQUEST FOR PROPOSAL (RFP) NO. 18-008
Water and Wastewater Treatment Chemicals

Addendum No. 13
Town of Purcellville Specifications Revisions (Second)

This Addendum No. 13 replaces Line Item #051 (Sodium Bisulfite) for Line Item #052 (Sodium Bisulfite 40%) for the Town of Purcellville in Section V and Table A – Price Proposal Form of RFP #18-008, as follows:

Line Item #	Chemical	Unit	Estimated Quantity per Annum	Unique Chemical Specifications	Applicable Standards	Unique Delivery Requirements
051	Sodium Bisulfite	Gallons	660	Must have product content of 38% liquid sodium bisulfite free of adulterants or impurities which might cause hazards or stoppage in the operation of standard water and wastewater treatment equipment.	<ul style="list-style-type: none"> • Must meet AWWA Standard B60 (latest edition) • Must meet VDH regulations • Must meet US EPA Primary Drinking Water Standards 	The liquid Sodium Bisulfite shall be shipped via 55-gallon drums which meet the cleanliness required in drinking water treatment. Product delivery truck shall be capable of offloading to above ground chemical storage tank.
052	Sodium Bisulfite 40%	55-gallon Drums	12	Must have product content of 38% liquid sodium bisulfite free of adulterants or impurities which might cause hazards or stoppage in the operation of standard water and wastewater treatment equipment.	<ul style="list-style-type: none"> • Must meet AWWA Standard B60 (latest edition) • Must meet VDH regulations • Must meet US EPA Primary Drinking Water Standards 	The liquid Sodium Bisulfite shall be shipped via 55-gallon drums which meet the cleanliness required in drinking water treatment. Product delivery truck shall be capable of offloading to above ground chemical storage tank.

All other terms and conditions of the RFP remain unchanged.