



REQUEST FOR PROPOSAL (RFP) NO. 18-008
Water and Wastewater Treatment Chemicals

Addendum No. 8
Town of Leesburg Specifications Revisions

This Addendum No. 8 revises the chemical specifications for the Town of Leesburg in Section V and Table A – Price Proposal Form of RFP #18-008, as follows:

Line Item #029 is deleted in its entirety and Line Item #030 is added, as follows:

Line Item #	Chemical	Unit	Estimated Quantity per Annum	Unique Chemical Specifications	Applicable Standards	Unique Delivery Requirements
029	Hydrofluosilicic Acid (25%)	30-gallon Drums	170	<ul style="list-style-type: none"> • Product must consist of not less than 23% solution hydrofluosilicic acid H₂SiF₆. • Product shall not contain more than 0.020% heavy metals expressed as lead. • Product shall be water white to straw yellow and free of suspended matter. 	Must meet AWWA Standard B703 (latest edition)	Deliver amount to Leesburg will be approximately 800 – 1,400 gallons per delivery due to the size of onsite chemical storage tanks.
030	Hydrofluosilicic Acid (25%), Bulk	Tons	25	<ul style="list-style-type: none"> • Product must consist of not less than 23% solution hydrofluosilicic acid, H₂SiF₆. • Product shall not contain more than 0.020% “heavy metals” expressed as lead. • Product shall be water white to straw yellow in color and free from suspended matter. 	Must meet AWWA Standard B703 (or latest edition)	Deliver amount to Leesburg will be approximately 800 – 1,400 gallons per delivery due to the size of onsite chemical storage tanks.

All other terms and conditions of the RFP remain unchanged.