

Blue Plains Energy Projects

Presented to:
COG Energy Advisory Committee


Salil Kharkar, P.E.
Director of Process /Engineering
DC Water – Blue Plains

November 15, 2012




Agenda

1. DC Water energy use at Blue Plains
2. Power Generation
3. Energy Saving Opportunities






DC WATER Energy Consumption



Based on invoices
2009 electricity based on PEPCO metering data



Blue Plains Electricity Used, kwh/day



PF Humidity: 70%		Wind: NE 5 mph		24176 KW	
Filter Influent			Outfall		
ORP			F-7 D-23		
ODD	506	mV	pH	6.49	6.53
EVEN	530	mV	DO	8.77	9.74
			OP (Ortho-Phos)	0.02	PPM
			NH3 (Ammonia)	0.10	PPM
			NO3 (Nitrate)	2.13	PPM
			NO2 (Nitrite)	0.10	PPM


Units	Limit	Date	Alarm Type	Name	Description	Net Alias	AY	Value	Q	Units	Limit
		11/13/2012 1:02:41 PM	ALARM	FWL_318	NIT WSP B SEAL WTR FLOW	PCCSNET2	E				
		11/13/2012 11:01:21 AM	ALARM	QDF07312	GSL51 EXHAUST FAN 9W AUTO FAIL	PCCS	B	ALARM 1			
		11/13/2012 11:01:17 AM	ALARM	QDF07315	GSL51 EF DMPR 9W AUTO FAIL	PCCS	B	ALARM 1			
		11/13/2012 10:27:14 AM	ALARM	FL_61212A	GT2 SLDG PMP 28 SUCT PRES	PCCS	H	LOW 1			
		11/13/2012 10:07:10 AM	ALARM	ZLA76013	CNTFG09 SL VLV FAIL TO CLOSE	PCCSNET2	K				
		11/13/2012 9:16:46 AM	ALARM	ZLA_30901C	NRX 09 SG-NRI 09C FAIL TO CLS	PCCSNET2	E				
		11/13/2012 7:45:08 AM	ALARM	ZF_2011D	SEC RX 1 SG-SRI1D FAIL STATUS	PCCS	D	FAIL 1			
		11/13/2012 6:30:25 AM	ALARM	XC_72492	SRP-2C COMMON ALARM	PCCSNET2	K				
		11/13/2012 5:04:06 AM	SENSOR	S10618	RWWPS2 BE SPEED	PCCS	A	-1.25	B	PCT	

Blue Plains AWWTP






Existing Flow Diagram



Biosolids Layout






Biosolids Project Site



Digester Overview




THP Slab/Pre-dewatering




Digester #3




Turbines



Gas Conditioning




Gas Blowers



Turbine Savings


10 MW Net Power Output

Financially \neq 10 MW of \$\$





New ENRF Facilities



40 MG of Denit Volume



Deep Channels and Rx




1 BGD ML PS

3 MW Additional Power
For ENRF



TDPS/ECF



12 MW Additional Power For TDPS/ECF




Power Math


- Recent Past 33 MW
- Present Usage 25 MW
- CHP (10 MW Net) 15 MW
- ENRF (+3 MW) 18 MW
- Other Upgrades (2 MW) 20 MW
- TDPS/ECF (+12 MW) 32 MW





Breakdown of Electricity Consumption Blue Plains





RWWPS1(West)




RWWPS2(East)







Deammonification






Filtrate Deammonification





ELECTRICAL DEFINITIONS
HELP



9.5 Miles of Fiber Optic Cable for Data Highway 

1 Mile of Fiber Optic Cable for Remote I/O 


23 DCUs Installed 

33 RIOs Installed 

31 Operator Workstations (OWS)

6 Operator Interface Terminals (OIT)

32,500 I/O Points Terminated






PF Humidity: 70% Wind: NE 5mph		24176 KW			
Filter Influent		Outfall		OP (Ortho-Phos) 0.02 PPM	
ORP		F-7 D-23		NH3 (Ammonia) 0.10 PPM	
ODD	506 mV	pH	6.49 6.53	NO3 (Nitrate) 2.13 PPM	
EVEN	530 mV	DO	8.77 9.74	NO2 (Nitrite) 0.10 PPM	






July/Aug 2012





Aug/Sept 2012

8.21.2012-9.19.2012





PJM Response Program

Demand Response Program

- Reduction of electric demand at the end-use level
- Help meet regional supply during high-demand periods or grid instability (hot weather, loss of generating capacity)

PJM Pays for the Ability to Shed Load and/or Use Existing Equipment

- Use existing equipment (i.e. emergency generators)
- User always receives payment even if event does not occur
- Commit to reduce load by reducing use (i.e. pumps and compressors)

Per PJM program requirements, events may only occur on business days from June through September and no more than ten events can occur per year for a maximum of six hours per event (60 hours/year)

Questions ?

- Digester gas
- Photovoltaic
- Wind
- Hydro