



**COMAR 26.11.36**  
**Distributed Generation**  
**Conceptual**  
**Amendments**

June 2013

# Background

## PJM electricity markets

- Research shows increased likelihood that emergency generators will be operating.
- Emergency Backup Generators can be very old and lack current technologies for emission controls.

2009 Maryland Distributed Generation regulation was a good start, recognized emerging markets and allowed flexibility.

- We now have conclusive numbers that show more than 9 tons of NO<sub>x</sub> can be emitted in one event/day in Maryland.



# Concerns

- The electricity markets deploy all eligible supply-side and demand-side resources without consideration of respective environmental performance.
- Demand Response (DR) programs provide financial incentives for the use of uncontrolled backup generators on the hottest summer days, when conditions would be most conducive to the formation of ground-level ozone.
- Most stationary generators are fired with diesel fuel and are uncontrolled.
- The combustion of diesel fuel releases significantly more NO<sub>x</sub> emissions per unit of power compared to the generation of electricity from well-controlled power plants.





# Proposed MD DG Regulations

- Revise definition of “Emergency Generator” to exclude all DR programs
  - A “Load shaving unit” is a generator that operates for other than emergency
  - New – all PJM Economic AND Emergency DR is load shaving
  - “Peak Shaving” is running a generator to offset a utility bill demand charge, under PJM program or not. Peak shaving is load shaving
- PJM Emergency DR generators will have emission restrictions for NO<sub>x</sub>



# Proposed MD DG Amendments

## COMAR 26.11.02

- Permit required for engines 500 hp or above. And ADD all load shaving engines, 100 hp and above.

## COMAR 26.11.36

- All DR programs are load shaving and need non-emergency permit. {Emergency DR = load shaving}
- NOx rate 1.4 g/bhp-hr for existing load shaving (prior to 2015)
- NOx rate 0.5 g/bhp-hr for new load shaving (after 2015)
- Delete 10 hour allowance for storm avoidance or other non-emergency hours.
- Delete purchase of NOx allowances to offset emissions in 2015.

# How to comply


- To meet strict NOx emission rates, NOx controls will likely need to be installed. Manufacturer Guarantee.
- Install new Tier 4 generator. EPA Certified.
- Permits will need to be obtained or revised.
  - MDE will require all generators in any DR Program or performing Peak Shaving to obtain a Permit to Construct (PTC)
  - Load shaving units are permitted with 8760 hours
  - Multiple engines and other equipment on site can trigger Permit to Operate (PTO).

Alternative, don't run generator for DR event,  
instead reduce KW usage only,  
and still get paid.

# Reasons for Proposed Amendments


Why more strict now?

- Tighter federal ozone standard and Maryland 2008 Ozone Status
- Need for local NO<sub>x</sub> controls
- PJM DR expansion in the market may preclude cleaner generation
- Maryland CSP reports confirm generators are running
- To adopt the OTC Model Rule standards





# Demand resources growing in New England and PJM



Data from ISO New England and PJM website



# PJM Future

- PJM Market Analyst predicts number of Emergency DR events will increase from 1-4 per year to 5-9 per year based on market growth.
- PJM is evolving programs to ensure reliability.
- Complexity in the market and possible future programs with unlimited hours of availability have provoked the Department to review regulations.



# OTC Model Rule 2011



– Emergency generators are part of Demand Response Program and would be considered non-emergency and would require emission limit for NO<sub>x</sub>, HC, CO and PM.

- Emergency generators can only run in “true emergency”, maintenance and testing. No other non-emergency run time.
- Emergency definition contains reference to 5% voltage or transmission deviation as an emergency.

# Other States

- DE & NJ – Generators in any DR program need to permit as non-emergency with required emission limits
- MA, NH & VA - Generators registered as emergency can be in “Emergency DR” only – equivalent of NERC EEA Level 2

# Questions

