Climate Change Vulnerability Assessment, Adaptation, and Mitigation Plan (CCVAAMP) Briefing

Metropolitan Washington Council of Governments Water Resources Technical Committee, January 7, 2022



Agenda

- CCVAAMP Contract Scope & Drivers
- Climate Analysis & Projections
- Facility Vulnerability Assessment & Adaptation Planning
- Linear Assets Vulnerability Screening
- Climate Change Design Guidelines
- Greenhouse Gas Inventory Progress (Mitigation)



Contract Scope & Drivers




Purpose of WSSC Water's CCVAAMP

- Purpose of study
 - Provide WSSC Water with understanding of future climate conditions, risks, and adaptation strategies.
 - Continue tracking greenhouse gas (GHG) emissions and developing GHG mitigation planning to achieve WSSC goals.
- Objectives/scope
 - Determine local climate change effects: Sea level rise, rainfall, and temperature projections
 - Identify vulnerabilities and risks: Flooding, electrical supply
 - Identify resilience and mitigation strategies: Facility adaptations, design guide, GHG mitigation planning



Flood-Related Challenges Facing WSSC




Climate Analysis & Projections



Sea-Level Rise Projections for Service Area:


High Tide (MHHW) projected to increase from 2.0 ft to 4.0 f in 2065





Rainfall Projections for Service Area

24-hour rainfall depth projected to increase 15% by 2065




100-year 24-hr Storm

Facility Vulnerability Assessments & Adaptation Planning




Flood modeling completed for riverine and coastal facilities using climate projections





Esri, HERE, Garmin, (c) OpenStreetMap contributors, and the GIS user community, Esri, HERE, DeLorme, MapmyIndia, © OpenStreetMap contributors, and the GIS user community



Geologic "Fall Line" between Piedmont and Coastal Plain geologic provinces

Photo credit: NationalAltas.gov

Facilities Investigated to Date

8 out of 18 found to be at risk from current or projected flooding

ta

oast

200 +	Facilities in GIS			
49	Facilities located in or near floodplain			
I 8	Facilities prioritized for future flood modeling			
18	Vulnerability assessments completed to date			

Anacostia WWPS #1 Anacostia WWPS #2 Broad Creek WWPS Western Branch WRRF Hyattsville WWPS Piscataway WRRF Anacostia Depot Colmar Manor WWPS Forest Heights WWPS Fort Foote WWPS

Air Park WPS Decatur Street WWPS Hyattstown WRRF Marlboro Meadows WWPS Parkway WRRF Reddy Branch WWPS Rocky Gorge WPS



Riverine



Risk Assessment / Alternatives Development

-Major assets located below new Design Flood Elevation

- I. Identify all assets at risk below recommended design flood elevation (DFE).
- 2. Determine Level of Service (LOS) of all assets at risk.
- 3. For high LOS assets under the DFE, develop asset-level strategy.
- 4. For all buildings at risk, develop building-level strategies.
- 5. Calculate benefit of adaptation.
- 6. Compare benefits to cost of flood-proofing alternatives.
- 7. Develop project recommendations.



Water and Wastewater Facility Level of Service

Wastewater Treatment Process Level-of-Service Designations

Maintenance of hydraulic capacity



Primary treatment liquid processes and disinfection

Secondary treatment liquid processes

Solids treatment processes



Solids treatment processes

Water Treatment Process

Finished water pumping,

distribution network

sensors, disinfection

Liquid filtration and

treatment processes


Level-of-Service Designations





|3

Sample Assessment: Rocky Gorge Water Pump Station





Adaptation Strategies for Plants and Pump Stations

Strategy	Resiliency Level	
No Action	No Protection	
Sandbagging	Low	
Temporary Barriers	Moderate	
Seal Building/ Control Room	Moderate/ Medium	
Construct Static Barrier	High	
Flood-proof Equipment	High	
Elevate Equipment	Very High	















Photo credit: Presray, FEMA, Global Industrial, Dis-Tran



Vulnerability and Adaptation Results (based on LOS I and LOS 2 assets at risk at 8 facilities found to be at risk of flooding)

	LOS I and LOS 2 Assets at Risk*			
Planning Horizon	Quantity	Cost of Replacement	Strategy Cost (Planning Level)	Benefit (Risk Avoided)
2065 100-year	71	\$12,720,000	\$1,104,000	\$3,931,700

*Level of Service (LOS) 1 and (LOS) 2 include assets that maintain the safety and protection of site personnel, maintain plant hydraulic capacity, and perform primary treatment for liquid processes.



Vulnerability and Adaptation Results (based on all assets at risk at 8 facilities found to be at risk of flooding)

	All Assets at Risk			
Planning Horizon	Quantity	Cost of Replacement	Strategy Cost (Planning Level)	Benefit (Risk Avoided)
2065 100-year	801	\$113,790,000	\$2,561,000	\$27,321,700



Linear Assets Vulnerability Screening





Flood Vulnerability Screening of Linear Assets

- Objective: Assess vulnerabilities of WSSC Water collection and distribution system assets for a projected 2065 100-year flood event
- Electrical and Mechanical (E/M) Asset Damage Vulnerabilities
 - Damages can result in operational impacts and repair/replacement costs
 - The CCVAAMP FY21 screening identified location and flood depth in the vicinity of assets
- Rainfall Dependent Inflow and Infiltration (RDII) Vulnerabilities
 - Component of inflow directly due to rainfall entering the sewer system through manhole covers, structures, illegal connections or cross-connections
 - The CCVAAMP FY21 screening identifies location and flooding depth of manhole rims to provide a focus for potential RDII concern areas




GIS-Based Vulnerability Assessment Screening








Sewer Screening – Total Number of Potentially Vulnerable Electrical and Mechanical (E/M) Assets (2065 100-year Event)



Grinder Pumps Meters Valves - Control




Sewer Screening – Percentage of Manholes Flooded (2065 100-year Event)





Water Screening – Total Number of Potentially Vulnerable Electrical and Mechanical (E/M) Assets (2065 100-year Event)





Linear Asset Screening – Top Ranked Sewer Basin Level Summary

- Larger number of potential RDII* points located across the service area
 - Condition assessment information needed to characterize RDII vulnerability

Rainfall Dependent Inflow & Infiltration

Sewer Basin	# of Water E/M Assets	# of Sewer E/M Assets	# of Potential RDII Source Assets
Paint Branch	16	I	2,892
Beaverdam Branch	17	5	I,385
Piscataway Creek	2	17	4,134
Rock Creek	17	4	6,112
Sligo Creek	11	2	I,728
Cabin John	9	5	3,497
Northeast Branch	38	3	2,778
Lower Anacostia	14	10	733
Northwest Branch	24	6	3,343
Broad Creek	30	12	2,966
Western Branch	16	4	7,926
Seneca Creek	19	17	4,728
Parkway	11	7	I,294
Oxon Run	18	4	1,270

Highlighted sub-basins are top ranked for potential impact to water and sewer E/M assets <u>and</u> inflow sources.

24




Climate Change Design Guidelines



Design Guide for Protecting Facilities from Future Climate Extremes

- Guidance for flood protection criteria
 - Criteria for design of new facilities and protection of existing facilities
 - Outfall tailwater design elevations for treatment process
 - Site stormwater design guidance based on climate projections
- Guidance for resiliency of electrical and Instrumentation & Controls systems
- Greenhouse gas emissions reporting guidance for new projects





Existing WSSC Water Flood Protection Guidance for Facilities

Facility Type	Guidance	Paragraph Reference
Drinking Water Facilities		
Water Supply & Treatment	Protect to at least the 100-year flood elevation or the maximum	2.20 ^a
Plant Access Roads	flood of record	
Water Pump Stations	Pumping station to be elevated to at least 3 feet above the 100-year flood level or highest known flood elevation, whichever is higher	6.1.1(a) ^a
Finished Water Storage	Lowest elevation of the floor and sump floor of ground level reservoirs shall be placed above the 100-year flood elevation or the highest flood of record, whichever is higher	7.0.2(a) ^a
Wastewater Facilities		
Wastewater Pump Stations	Protect from physical damage by the 100-year flood, should remain fully operational and accessible during the 25-year flood	41.1 ^b
Wastewater Treatment Plants	Protect from physical damage by the 100-year flood, should remain fully operational and accessible during the 25-year flood	51.2 ^b
	idance is Recommended Standards for Water Works (10-States, 2012) ity guidance is Recommended Standards for Wastewater Facilities (10-States	5, 2014)



Basis of Recommended Standard

- **Objective:** Protect WSSC assets for their entire service life
 - Resilience during flood events
 - Avoid costly equipment repairs/replacements

Design Flood Elevation

- CCVAAMP Studied Facilities: 100-year 2065 water surface elevation + freeboard
- Other Facilities: FEMA 100-year water surface elevation + freeboard + climate safety factor

• Freeboard:

- American Society of Civil Engineers (ASCE) 24-14 Flood Resistant Design and Construction
- Riverine = 1.0 foot, Coastal = 2.0 feet
- Climate Safety Factor (S.F):
 - Calculated based on comparison of existing to future water surface elevations in riverine and coastal areas
 - Riverine = 1.5 feet, Coastal = 2.0 feet



Basis of Recommended Standard (contd.)

- Objective: Protect WSSC assets for their entire service life
- Design Flood Elevation


	Facilities Studied in CCVAAMP
Riverine	Modeled 2065 100-year WSEL + 1-foot freeboard
Coastal	Modeled 2065 100-year WSEL + 2-foot freeboard
	Facilities Not Studied in CCVAAMP
Zone A (A,AE,AI-30,AH,AO,AR,A99)	FEMA 100-year WSEL + 1.5-foot climate S.F. + 1-foot freeboard
Coastal Zone V & A (V,VE,VI-30)	FEMA 100-year WSEL + 2.0-foot climate S.F. + 2-foot freeboard



Greenhouse Gas Reduction (Mitigation) Progress



What the GHG inventory includes...






WSSC Water GHG Reduction Goals

- WSSC's current GHG Reduction Goal:
 - 10% reduction every 5 years
 - 60% reduction from 2005 levels by 2035
 - 90% reduction from 2005 levels by 2050

• May be updated pending current legislation proposed in MD



Emissions Impacts of Current Projects in 2035 (tonnes CO₂e/Yr)





Projected Future Emissions, CIP Projects, and Wind/REC Purchase versus WSSC Reduction Goal

